

Ref.No: 116 /CFO/KZK/COLLEGE/NOC/2022.

Dated:19/09/2022

To,  
The President  
S.R.N Mehta School,  
sy no 79/1, Azadpur,  
Sedum road,  
Dist Kalaburagi  
KARNATAKA  
Sir,

Sub: Issue of "Fire Safety recommendation" to S.R.N Mehta School ,sy no 79/1, Azadpur  
,Sedum road, Dist Kalaburagi KARNATAKA

Ref : C.NO /RFO/KR/2022 Date 06/09/2022

\*\*\*\*\*<><><><><>\*\*\*\*\*

With reference to the subject above cited, the premises of S.R.N Mehta School ,sy no 79/1, Azadpur , Sedum road, Dist Kalaburagi KARNATAKA was inspected by Regional fore officer kalaburagi on 12/09/2022 with respect to fire prevention, fire fighting and evacuation measures to be Provided in the above premises and Submitted building details as under.

Details of the building / premises :-


01	Name and Address of the Applicant.	:	S.R.N Mehta School ,sy no 79/1, Azadpur ,Sedum road, Dist Kalaburagi KARNATAKA
02	Name and Address of the premises.	:	S.R.N Mehta School ,sy no 79/1, Azadpur ,Sedum road, Dist Kalaburagi KARNATAKA
03	Name and address of the Building owner	:	<b>The President</b> S.R.N Mehta School ,sy no 79/1, Azadpur ,Sedum road, Dist Kalaburagi KARNATAKA
04	Number of buildings	:	01 No's of Building.
05	Number of floors	:	Lower upper ground +03 floors
06	<u>Floor-wise details of occupancy:-</u>		
	Lower Ground floor	:	pump room, store room, car parking area
	Upeer Ground Floor	:	class room-15 ,waiting hall-01, lab -02 , admin room 01
	01 <sup>st</sup> floor	:	class room-15 ,waiting hall-01 lab -02 , admin room 01
	2 <sup>nd</sup> floor	:	class rooms-10, admin room 01
	3 <sup>rd</sup> floor	:	class room-09



			pipe. From this riser single headed hydrant valves shall be provided at each landing. An hose reel hose of 30.00 Mtrs. length with M.S. drum
08	Water storage tank	Provided 4 No of 2,000 liters water tank	Recommended to provide 02 Nos of over head tanks of capacity 10,000 Ltrs and 50000 ltrs capacity of sumps shall be provided
09	Fire order	Not providede	Recommended to provide Notice boards indicating with Details of action to be taken by the employees in case of an Emergency/fire has been displayed with telephone Number of Kalaburagi Fire Station i.e.08472-220101 & 101 and of near by Ambulance Service
10	Fire fighting training	Not providede	<b>Recommended to provide</b> 40% of the employees should be got trained in the prevention & fire fighting at the R. A. Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore. Within 6 month of date of issue this recommendations

Hence This "Fire Safety recommendation" is issued to S.R.N Mehta School ,sy no 79/1, Azadpur ,Sedum road, Dist Kalaburagi KARNATAKA . subjected to strict adherence of the condition as laid down in this NOC and to conduct mock drills periodically and the management must not extend the height of the building beyond 15.0 mts and this "Fire Safety recommendation" is valid for a period of one year from the date of issue.

Yours faithfully

  
19/9/22  
**CHIEF FIRE OFFICER  
KARNATAKA FIRE AND  
EMERGENCY SERVICES  
KALABURAGI ZONE  
KALABURAGI-585103**

Copy to: the regional fire officer kalaburagi.