



AFFILIATED TO VTU BELAGAVI AND
APPROVED BY AICTE, NEW DELHI

Hyderabad Karnataka Education Society's

Poojya Doddappa Appa College of Engineering

KALABURAGI - 585 102 - KARNATAKA - INDIA

Phone : 08472-224360-220019-220349 - Offi. : 220172 - Resi.: 228479 - Fax : 255685

Email : principal@pdaengg.com - principalpda@yahoo.com - website : www.pdaengg.com

ಹೈದರಾಬಾದ್ ಕರ್ನಾಟಕ ಶಿಕ್ಷಣ ಸಂಸ್ಥೆಯ

ಪೂಜ್ಯ ದೊಡ್ಡಪ್ಪ ಅಪ್ಪ ತಾಂತ್ರಿಕ ಮಹಾವಿದ್ಯಾಲಯ

ಕಲಬುರಗಿ - ೫೮೫ ೧೦೨ - ಕರ್ನಾಟಕ

PDACEK/CED/TEST/2022/ 546

To,
S.R.N. Mehta CBSE School
Sy.No 79/1, Azadpur, Sedam Road,
Kalaburagi

Date: 15.06.2022

Sir,
Sub: Test results of water (R.O) sample supplied by you reg.
Ref: Your Letter No: NIL/Dated: 08.06.2022
Rec. No: U46697/2022-23/Date: 08.06.2022/Rs.850/-
Project: - Drinking Purpose.

With reference to above-cited subject, Test results of Water sample supplied by you are as follows

Sl. No.	Parameter	Results	As peris 10500: 1991 Drinking water specification	
			Requirement (Desirable limits)	Permissible limits(if no alternative source)
1	Total Hardness	60 mg/l	300 mg/l	600 mg/l
2	Chlorides	60 mg/l	250 mg/l	1000 mg/l
3	p ^H	6.8	6.5 to 8.5	No relaxation
4	Calcium Hardness	40 mg/l	75 mg/l	200 mg/l
5	Magnesium Hardness	20 mg/l	30 mg/l	100 mg/l
6	Alkalinity	62 mg/l	200 mg/l	600 mg/l

This is for your kind information.
Thanking you.

Yours faithfully

Principal