

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 11/02/2025

It is certified that an inspection team headed by EXECUTIVE ENGINEER, DIVISION, KALBURGI

(Name of Officers with designation) from K.U.W.S.D. BOARD PHED

inspected the S. R. N. MEHTA SCHOOL, SY No. 79/1, AZADPUR, KALBURGI

(Name & Address of the school) on 11.02.2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. DFL/KLB/N-PVT/WATER/002/2025/132 dated 11/02/2025

of Chief food Analyst, Divisional food lab, KALBURGI (PHED Lab) certified that the

S. R. N. MEHTA SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 10/02/2029.

  
EXECUTIVE ENGINEER  
K.U.W.S. & D. Board

Signature with Seal: Division, KALBURGI

Name: SRI. NARSIMHA REDDY

Designation: EXECUTIVE ENGINEER

Name & Address of the Office / Department : K.U.W.S.D. Board,

Opp Mini Vidhan Soudha  
Awanshahi road, Kalburgi

To Principal, S.R.N. Mehta  
School, Sy 79/1, Azadpur, Sedam Road Kalburgi  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies





GOVERNMENT OF KARNATAKA  
Divisional Food Laboratory Kalaburagi Division  
First Floor, Central Bus Stand, Kalaburagi -585102  
Phone: 08472-260427 E mail: dflgulabarga@gmail.com

No: DFL/KLB/N-PVT/WATER/002/2025

1/32

Date: 11.02.2025

To  
Principal  
S.R.N. Mehta School  
Sy.No.79/1,Azadpur,  
Sedam Road  
Kalaburagi- 585 106.

Ref. No: Nil;

Date : 06/02/2025;

Received One Water sample from Principal S.R.N. Mehta CBSE School  
Kalaburagi for analysis. Received on : 07-02-2025;


Challan No.: CR0225021000507435; Date : 07/02/2025; Bank : SBI Kalaburagi; Amt: 5000

Date of analysis : 07/02/2025 To 11/02/2025

Sl No	Quality Characteristics	Results Mg/l. (Except pH and turbidity)	Requirement as per IS 10500:2012 Mg/l. Max.	Permissible limit as per IS 10500:2012 in the absence of alternate source Mg/l. Max.
1	Odour	Agreeable	Agreeable	Agreeable
2	Taste	Agreeable	Agreeable	Agreeable
3	pH	6.6	6.5-8.5	No relaxation
4	Turbidity	0.1	1	5
5	Total dissolved solids	119.3	500	2000
6	Total Hardness (as $\text{CaCO}_3$ )	64.0	200	600
7	Calcium (as Ca)	14.4	75	200
8	Chlorides (as Cl)	20	250	1000
9	Alkalinity	62	200	600
10	Magnesium (as Mg) mg/l, Max	12.10	30	100
11	Flouride (as F)mg/l,Max	0.26	1.0	1
12	Nitrate(as $\text{NO}_3$ )mg/l,Max	3.0	45	No relaxation
13	SULPHATE(as $\text{SO}_4$ )mg/l,Max	30.1	200	400
14	Iron(as Fe),mg/l,Max	0.08	0.3	No relaxation
15	Conductivity	252.1	-	-
16	Physical appearance	Satisfactory	Satisfactory	Satisfactory

**Opinion:-** The Water Sample conforms to the standards of purified drinking water as per above mentioned parameters.

"End of Report"

  
CHIEF FOOD ANALYST  
DIVISIONAL FOOD LABORATORY  
KALABURAGI DIVISION, KALABURAGI  
11/02/2025