OFFICE OF THE DISTRICT FIRE OFFICER
Karnataka Fire & Emergency Services
KALABURAGI DISTRICT
KALABURAGI - 585 103

Karnataka State Fire and Emergency Services

No.115/DFO/KDK/RCC/2026 Dated:18/06/2026

To,
The Principal
Raj Naval Trust
M/S S.R.N. Mehta HS
Mehta Compound, Court Road, Kalaburgi – 585102.

Sub:- Issue of "Renewal of Compliance Certificate" with respect to fire prevention, fire fighting and evacuation measures maintained at Raj Naval Trust, M/S S.R.N. Mehta HS Mehta Compound, Court Road, Kalaburgi - 585102.

Ref: 1) Ref No 30/DFO/KLB/Dist/FSR/2023 Date 20/04/2024.
2) Applicant on Dated:09/06/2026.

With reference to the subject cited above, as per reference (1) Raj Naval Trust, M/S S.R.N. Mehta HS, Mehta Compound, Court Road, Kalaburgi - 585102 was inspected by the District Fire Officer, Kalaburagi, from the fire prevention, fire fighting and evacuation point of view. Fire safety recommendations were issued for the firefighting system to be installed within 03 months including training part.

As per reference (3) the school building was re-inspected by the District Fire Officer, Kalaburagi on 03/06/2026. The applicant has fulfilled all the recommendations made in the recommendation except the training part.

Hence, a "Renewal of Compliance Certificate" is issued for the above said S.R.N. Mehta HS building from the fire prevention, fire fighting and evacuation point of view and it is recommended to maintain the same in good working condition at all times. At least 40% of staff/employees should be trained in basic fire fighting at R.A. Mundkur Fire & Emergency Academy, Bannerghatta Road, Bengaluru within 15 day's.

This Renewal of Compliance Certificate is valid up to 17/06/2028 and it is renewable.

Your's Faithfully,

18/06/2026
DISTRICT FIRE OFFICER
Karnataka Fire & Emergency Services
KALABURAGI DISTRICT
KALABURAGI - 585 103

PRINCIPAL
SRN MEHTA
HIGH SCHOOL
1-22/C, Mehta Compound,
Court Road, KALABURAGI-85102.

SRN MEHTA SCHOOL
MANAGER