Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. Dated: 11/02/2025

It is certified that an inspection team headed by EXECUTIVE ENGINEER, DIVISION, KALBURGI

(Name of Officers with designation) from KUWS&D BOARD ~~PHED~~

inspected the S.R.N MEHTA SCHOOL, SY No: 79/1, AZADPUR, KALBURGI

(Name & Address of the school) on 11-02-2025 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. DFL/KLB/N-PVT/WATER/1002/2025/132 dated 11/02/2025 of Chief food Analyst, Divisional food lab, kalburgi (PHED Lab) certified that the S.R.N MEHTA SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 10/02/2029

EXECUTIVE ENGINEER
K.U.W.S. & D. Board
Division KALABURAGI

Signature with Seal: ...
Name : SRI. NARSIMHA REDDY
Designation : EXECUTIVE ENGINEER
Name & Address of the Office / Department : KUWS&D Board, Opp Mini vidhan Soudha Awan Shahi road, Kalburgi.

To Principal SRN Mehta School Sy 79/1 Azadpur Sedam Road Kalaburagi
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

SRN MEHTA CBSE SCHOOL
MANAGER

PRINCIPAL
S.R.N MEHTA SCHOOL
Sy No 79/1 Azadpur, Sedam Road
KALABURAGI

GOVERNMENT OF KARNATAKA
Divisional Food Laboratory Kalaburagi Division
First Floor, Central Bus Stand,Kalaburagi -585102
Phone: 08472-260427 E mail: dflgulabarga@gmail.com

No: DFL/KLB/N-PVT/WATER/002/2025 / 132 **Date: 11.02.2025**

To
Principal
S.R.N. Mehta School
Sy.No.79/1,Azadpur,
Sedam Road
Kalaburagi- 585 106.

Ref. No: Nil; Date : 06/02/2025;

Received One Water sample from Principal S.R.N. Mehta CBSE School Kalaburagi for analysis.Received on : 07-02-2025;
Challan No.: CR022502100050743S; Date : 07/02/2025; Bank : SBI Kalaburagi; Amt: 5000
Date of analysis : 07/02/2025 To 11/02/2025

Sl No	Quality Characteristics	Results Mg/lt. (Except pH and turbidity)	Requirement as per IS 10500:2012 Mg/lt. Max.	Permissible limit as per IS 10500:2012 in the absence of alternate source Mg/lt. Max.
1	Odour	Agreeable	Agreeable	Agreeable
2	Taste	Agreeable	Agreeable	Agreeable
3	pH	6.6	6.5-8.5	No relaxation
4	Turbidity	0.1	1	5
5	Total dissolved solids	119.3	500	2000
6	Total Hardness (as $caco_3$)	64.0	200	600
7	Calcium (as Ca)	14.4	75	200
8	Chlorides (as Cl)	20	250	1000
9	Alkalinity	62	200	600
10	Magnesium (as Mg) mg/l, Max	12.10	30	100
11	Flouride (as F)mg/l,Max	0.26	1.0	1
12	Nitrate(as NO_3)mg/l,Max	3.0	45	No relaxation
13	SULPHATE(as SO_4)mg/l,Max	30.1	200	400
14	Iron(as Fe),mg/l,Max	0.08	0.3	No relaxation
15	Conductivity	252.1	-	-
16	Physical appearance	Satisfactory	Satisfactory	Satisfactory

Opinion:- The Water Sample conforms to the standards of purified drinking water as per above mentioned parameters.

"End of Report"

11/02/2025
CHIEF FOOD ANALYST
DIVISIONAL FOOD LABORATORY
KALABURAGI DIVISION, KALABURAGI

SRN MEHTA CBSE SCHOOL
MANAGER

PRINCIPAL
S.R.N MEHTA SCHOOL
Sy No 79/1 Azadpur, Sedam Road
KALABURAGI